

Intake Data - Raw River Water Entering the Geren Island Water Treatment Facility

Sample Date	Microcystin		Cylindrospermopsin	
	Lab Reported Concentration ¹	Minimum Reporting Level ² (µg/L)	Lab Reported Concentration ¹	Minimum Reporting Level ² (µg/L)
8/1/2019	0.385	0.15	Not Analyzed ³	0.05
8/2/2019	0.503	0.15	Not Analyzed ³	0.05
8/3/2019	0.640	0.15	Not Analyzed ³	0.05
8/4/2019	0.579	0.15	Not Analyzed ³	0.05
8/5/2019	0.474	0.15	N/A - Instrument Error	0.05
8/6/2019	0.411	0.15	Not Analyzed ³	0.05
8/7/2019	0.620	0.15	Not Analyzed ³	0.05

* Updated microcystin data


¹The Lab Reported Concentration is a non-detect when the data concentration is less than the minimum reporting level. The unit µg/L is the same as micrograms per liter of water.

²The Minimum Reporting Level (RL)—is the lowest concentration at which an analyte - Microcystin or Cylindrospermopsin - can be detected in a sample and its concentration can be reported with a reasonable degree of accuracy and precision.

³Cylindrospermopsin has not been detected this algal season. Beginning July 15, 2019, cylindrospermopsin analyses will be done weekly rather than daily.

For more about cyanotoxins and drinking water advisories in Salem, visit: <https://cityofsalem.net/water-advisory>

Intake - Total Microcystin



Intake - Cylindrospermopsin

