

Intake Data - Raw River Water Entering the Geren Island Water Treatment Facility

<i>Sample Date</i>	Microcystin		Cylindrospermopsin	
	<i>Lab Reported Concentration</i> ¹	<i>Minimum Reporting Level</i> ² (µg/L)	<i>Lab Reported Concentration</i> ¹	<i>Minimum Reporting Level</i> ² (µg/L)
8/1/2019	0.385	0.15	Not Analyzed ³	0.05
8/2/2019	0.503	0.15	Not Analyzed ³	0.05
8/3/2019	0.640	0.15	Not Analyzed ³	0.05
8/4/2019	0.579	0.15	Not Analyzed ³	0.05
8/5/2019	0.474	0.15	Below Detection Limit	0.05
8/6/2019	0.411	0.15	Not Analyzed ³	0.05
8/7/2019	0.620	0.15	Not Analyzed ³	0.05
8/8/2019	1.258	0.15	Not Analyzed ³	0.05
8/9/2019	0.952	0.15	Not Analyzed ³	0.05
8/10/2019	0.716	0.15	Not Analyzed ³	0.05
8/11/2019	0.853	0.15	Not Analyzed ³	0.05
8/12/2019	0.915	0.15	Below Detection Limit	0.05
8/13/2019	0.541	0.15	Not Analyzed ³	0.05
8/14/2019	0.510	0.15	Not Analyzed ³	0.05
8/15/2019	0.360	0.15	Not Analyzed ³	0.05
8/16/2019	0.249	0.015	Not Analyzed ³	0.05
8/17/2019	0.172	0.015	Not Analyzed ³	0.05

* Updated microcystin data

¹The Lab Reported Concentration is a non-detect when the data concentration is less than the minimum reporting level. The unit µg/L is the same as micrograms per liter of water.

²The Minimum Reporting Level (RL)—is the lowest concentration at which an analyte - Microcystin or Cylindrospermopsin - can be detected in a sample and its concentration can be reported with a reasonable degree of accuracy and precision.

³Cylindrospermopsin has not been detected this algal season. Beginning July 15, 2019, cylindrospermopsin analyses will be done weekly rather than daily.

For more about cyanotoxins and drinking water advisories in Salem, visit: <https://cityofsalem.net/water-advisory>

