


Intake Data - Raw River Water Entering the Geren Island Water Treatment Facility

Sample Date	Microcystin		Cylindrospermopsin		Laboratory
	<i>Lab Reported Concentration</i> ¹	<i>Minimum Reporting Level</i> ² (µg/L)	<i>Lab Reported Concentration</i> ¹	<i>Minimum Reporting Level</i> ² (µg/L)	
6/3/2024	Non Detect at MRL	0.2	Non Detect at MRL	0.2	Willow Lake


¹The Lab Reported Concentration is a non-detect when the data concentration is less than the minimum reporting level. The unit µg/L is the same as micrograms per liter of water.

²The Minimum Reporting Level (MRL)—is the lowest concentration at which an analyte - Total Microcystin or Cylindrospermopsin - can be detected in a sample and its concentration can be reported with a reasonable degree of accuracy and precision.

Intake - Total Microcystin



Intake - Cylindrospermopsin



For more about cyanotoxins and drinking water advisories in Salem, visit: <https://www.cityofsalem.net/community/household/water-utilities/salem-s-drinking-water>